

Addendum No. 2 for
**SPANISH FORK CANYON
PIPELINE - REACH 3**

CONTRACT C-2009-03



**CENTRAL UTAH
WATER CONSERVANCY DISTRICT**

**(801) 226-7100
(801) 226-7150 FAX**

MAY 2009



ADDENDUM NO. 2 to
Spanish Fork Canyon Pipeline – Reach 3
Contract C-2009-03

May 13, 2009

The following ADDENDUM (1 page of text, 0 Drawings and 0 Attachments) shall be made part of the contract documents, and the bidder shall acknowledge receipt thereof on page B1-3 of the BID FORM.

VOLUME 1 - SPECIFICATIONS

- A2.1 Addendum 1, Item A1.8, line 2, CHANGE “Paragraph 1.3.H” to “Paragraph 1.4.H”.
- A2.2 Bid Form, pg B1-5, paragraph A.1, line 2, CHANGE “Part (E)” to “Part (D).”
- A2.3 Section 13115:
 - Paragraph 2.03.B.2, CHANGE to: “ Bare Weight:: per drawings”
 - Paragraph 2.03.B.3, CHANGE to: “Anode Wire: No.12, black, solid or stranded, TW or TWHN insulation.
 - Paragraph 2.07.B & C. Use No. 8 AWG or thicker wire only. CHANGE No. 6 references to No. 8.
 - Paragraphs 2.09 & 3.09. DELETE references to DC blockers and insulating flanges (none are on project).

VOLUME 2 - DRAWINGS

- A2.4 Dwg G-3, for Abbreviations “T” & “TEL”, after “TELEPHONE”, ADD “, TELECOMMUNICATION”.
- A2.5 Dwg C-1, ADD “Note: For this rock cut work UDOT will require a report/certification from a geotechnical engineer demonstrating to UDOT/CUWCD’s geotechnical engineer, Golder & Associates, that the Contractor-designed cut slopes will be stable.

END OF ADDENDUM NO. 2